

SAFETY SYSTEM®
YOUR PROTECTOR

Sir Safety System S.p.A. Single-member company
Wholly-owned subsidiary of Sir Holding Srl

Sir Safety System S.p.A. Single-member compart Wholly-owned subsidiary of Sir Holding Srl Via dei Fornaciai, 9 - Santa Maria degli Angeli 06081 Assisi - Perugia - Italy Tel.+39 075.8043737 - Fax +39 075.8048686

VAT Nr. IT 03359340548 Viale Europa 74 20090 Cusago Milano Tel. +39 02.90394575 Fax +39 02.90394441 export@sirsafety.com www.sirsafety.com





Name: ELECTRO glove class 1	Code: MA1815E0	MA18 SPECIAL PROTECTION GLOVES

Description

Dielectric glove Class 1

Length: 36 cm

Thickness: mm 1,5 (tolerance +0,6) in Natural Latex

Insulation: 10.000 V Proof test voltage: 10 kV Withstand voltage: 7,5 kV

Supplied in a special polyethylene sealed case.

Category	Colours YELLOW	Available Sizes Made to order: 8 - 11 In stock:
Quantity/Carton	EC Standards IEC 60903 Acid, Oil, Ozone:R Resistant to very low temperatures:C	Important Information Protection against contact with voltage-carrying parts under voltage. Make sure the garment is in good condition, undamaged and clean before use. Once you become aware of a damage, you should immediately replace it. We recommend six-monthly voltage test. Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between Í Ä » C. If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene etc. Then wash with water at a temperature below G » C and soap and dry thoroughly.

Dexterity

Storage and cleaning