

TECHNICAL SHEET

Sir Safety System S.p.A. Single-member company Wholly-owned subsidiary of Sir Holding Srl Via dei Fornaciai, 9 - Santa Maria degli Angeli 06081 Assisi - Perugia - Italy Tel.+39 075.8043737 - Fax +39 075.8048686 VAT Nr. IT 03359340548 Viale Europa 74 20090 Cusago Milano Tel. +39 02.90394575 Fax +39 02.90394441

export@sirsafety.com www.sirsafety.com





Name: ELECTRO glove class 00 Code: MA1818E0 MA18 SPECIAL PROTECTION GLOVES

Description

Dielectric glove Class 00 Length: 36 cm Thickness: mm 0,5 in Natural Latex Insulation: 2.500 V Proof test voltage: 2,5 kV Withstand voltage: 0,5 kV

Supplied in a special polyethylene sealed case.

The product has been designed and manufactured to complywith Regulation (EU) 2016/425 and subsequent amendments.

Category	Colours	Available Sizes
	YELLOW	In stock: 8 - 11
Quantity/Carton 1 Dexterity	EC Standards IEC 60903 Acid, Oil, Ozone:R Resistant to very low temperatures:C	Important InformationProtection against contact with voltage-carrying parts under voltage.Make sure the garment is in good condition, undamaged and clean before use. Once you become aware of a damage, you should immediately replace it.We recommend six-monthly voltage test.Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between Í Étí » C.If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene,